



**FIRE EXTINGUISHER
MONTHLY INSPECTION LOG**

Business Name/Address:

Year: _____

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Monthly inspection includes:

- Verify that extinguisher is in assigned location.
- Extinguisher is clearly visible and access is not obstructed.
- Fire extinguisher is fully charged (gauge in in green zone).
- Nozzle is free of obstruction.
- Lock pin is in place.
- Service tag (yellow tag) is attached and current.